



TRAVIS COUNTY EMERGENCY SERVICE DISTRICT #4

FIRE - RESCUE - EMS

11800 N. Lamar Blvd.
Suite 4B
Austin, TX 78753

Office (512) 836-7566
Fax (512) 832-8389
www.esd4.org

Address:

Date:

Structural Triage Checklist

Construction

Roof /Siding - Wood Shakes	YES	NO
Roof - Combustible?? - (shingles/tiles vs. wood)	YES	NO
Deck/ Gables - NOT enclosed underneath	YES	NO
Power lines - Overhead within 30ft of structure	YES	NO
Driveway - Longer than 200 ft, or not able to back brush truck down	YES	NO
Vehicles parked within 30 ft of structure	YES	NO

Topography

Trees - overhanging roof	YES	NO
Trees / Brush - <u>NOT</u> Thinned within 30ft of structure	YES	NO
Slope greater that 20% anywhere within 30 feet of structure	YES	NO
Location is a Ridge, Saddle, or Box Canyon	YES	NO

Notes and Special Hazards:

TOTAL "YES" COUNT:

Total Number of freestanding structures on property:

0-2 DOESN'T NEED DEFENDING :: 3-5 DEFEND AGGRESSIVELY :: 6-7 DEFEND CAUTIOUSLY :: 8-10 INDEFENSIBLE

(circle category based on number of "yes's")